

## Daily Inspection Items

- Walkways/deck and exits are clear, clean, and free of debris
- Drain covers, vacuum fitting covers, skimmer equalizer covers, and any other suction outlet covers are in place, secure, and unbroken
- Skimmer baskets, weirs, lids, flow adjusters, and suction outlets are free of any blockage
- Inlet and return covers and any other fittings are in place, secure, and unbroken
- Safety warning signs and other signage are in place and in good repair, including emergency instructions and phone numbers
- Entrapment prevention systems are operational
- Recirculation, disinfection systems, controller(s), and probes are operating as required
- Secondary disinfection systems and/or supplemental treatment systems are operating as required
- Underwater lights and other lighting are intact with no exposed wires or water in lights
- Slime and biofilm has been removed from accessible surfaces or aquatic venues, slides, and other aquatic features
- Doors to nonpublic areas (chemical storage spaces, offices, etc.) are locked
- First aid supplies are stocked
- Emergency communication equipment and systems are operational
- Fecal/vomit/blood incident contamination response protocols, materials and equipment are available
- Water features and amenities are functioning in accordance with manufacturers recommendations
- Fencing/barriers, gates, and self-latching or other locks are tested and are intact and functioning properly, and barriers do not have nearby furniture to encourage climbing
- Drinking fountains are clean and in functional condition
- Electrical devices are in good working condition and meet the requirements specified in the National Electrical Code and Model Aquatic Health Code
- Alarms, if required, are tested and functioning properly
- Assessing water clarity such that the bottom and objects in the pool are clearly visible